

April 22, 2020

Uzin Utz North America, Inc.

Subject: **Report of Results for Product Testing**
Project Name: UZIN NC 886
TEC Services Project No: TEC 18-1478
TEC Laboratory No: 20-347

SGS TEC Services is an AASTHO R18, ANS/ISO/IEC 17025:2005 and Army Corp of Engineers accredited laboratory. Presented below is a SGS TEC Services verified summary of test report dated April 22, 2020 on the product designated as “UZIN NC 886”.

The UZIN NC 886 Skim and Repair Compound was ordered and randomly selected at a flooring supply company of our choice, and delivered to our Lawrenceville, GA facility in March of 2020. SGS TEC Services prepared the UZIN NC 886 sample following the UZIN recommended mid-range water to material ratio, mixing and curing procedures. Testing was performed in accordance to ASTM C109-20a *Standard Test Method for Compressive Strength of Hydraulic Cement*. The test results presented only pertain to the samples tested.

ASTM C109/C109M – 20a test method	NC 886
28 Day Compressive Strength	Exceeds 3000 psi

SGS TEC Services appreciates the opportunity to provide our professional services for this project. If you have any questions regarding this report, or if we can be of further assistance please contact us at 770-995-8000.

Sincerely,
SGS TEC Services

Dean T. Roosa
Project Manager

Shawn P. McCormick
Laboratory Principal